

	INTERNAL ELECTRICAL SUPPLY CONTROL FORM		
		Date of Issue	11 / 07 / 2025
		Date of Validity	11 / 07 / 2026

1. GENERAL INFORMATION

Name of apartment	UYGUN CLEOPATRA 2 RESIDENCE
Field of activity	RESIDENCE
Address	KIZILARPINARI NEIGHBORHOOD 1512. STREET NO:9
Mobile Phone Number	0507-220-8531
Date of Issue	11/07/2025
Control Reason	☐ Periodic ☒ Correction ☐ New Plant

2. THE METHOD OF PERIODIC CONTROL

MEASURING DEVICE	
Brand-Model	
Serial Number	
Error Class	
DEVICE CALIBRATION INFORMATION	
Calibrating Institution	
Calibration Approval Date and Number	
Validity Period	
METHOD OF MEASUREMENT	1. Regulation on Grounding in Electrical Installations, 2. Electrical High Current Facilities Regulation, 3. Regulation on Internal Electrical Installations

	INTERNAL ELECTRICAL SUPPLY CONTROL FORM		
		Date of Issue	11 / 07 / 2025
		Date of Validity	11 / 07 / 2026

3. TEST, EXPERIMENT, INSPECTION		DETECTION and CONSIDERATION
No	BRANCH	CONDITION
1.	Is the branch line underground or above ground?	Uygundur.
2.	Is there foundation grounding?	Appropriate.
ELECTRICAL ROOM, CABLE SHAFT, ELECTRICAL COUNTER and DISTRIBUTION PANEL		
3.	Do the electrical room and cable shaft comply with the relevant regulations and standards?	Appropriate.
4.	Have safety precautions been taken against direct and indirect touching of the panels?	Yes.
5.	Are the meter and measurement sections lockable and sealed?	Yes.
6.	Is the main distribution panel has got 300milliamp fire protection input switch?	No.
7.	Are there any death danger signs on the electrical panels?	No.
8.	Are the input switch current values in the main distribution panel appropriate?	No
9.	Are cable sections, types and colors appropriate? Partially must be	controlled.
10.	Are fuse and circuit breaker amperages suitable for selective selectivity?	No
11.	Is there any heating at the fuse connection points?	Partially.
12.	Have the necessary grounding connections been made to the potential equalization panel?	No.
13.	Are the internal connections of all electrical panels appropriate?	No
14.	Are the main distribution panels physically appropriate?(Decay,Mold etc.)	Appropriate.
15.	Are the busbar connection points suitable in the main distribution panel?	Appropriate.
16.	Are there groundings on the covers of electrical panels?	No.
17.	Are there groundings in electrical panels?	No.
18.	Are there warning signs in meter rooms and on all general electrical panels?	No.
POOL ENGINE ROOM		CONDITION
19.	Are all electrical installations such as panels, switches, sockets, pipes in the pool machine rooms in compliance with the standards?	No.
20.	Does the lighting system in pool machine rooms comply with the relevant standards?	No.
21.	Is the installation installed on antigron cable? Main supply is antigran, but engine feeds NYAF cable.	
22.	Are there engine body groundings in the pool engine room?	No
23.	Are metal bodies, engine room stairs, etc. in the pool engine room grounded?	No
24.	Are the fuse and circuit breaker amperages in the pool engine room suitable for selective selection?	No
25.	Are there 30 milliamp residual current protection relays in the panels located in the pool engine room?	No
26.	Are there thermal motor protection relays on the motor panels and motors in the pool machine room?	No

	INTERNAL ELECTRICAL SUPPLY CONTROL FORM		
		Date of Issue	11 / 07 / 2025
		Date of Validity	11 / 07 / 2026

27.	Is protection provided by automatic switches equipped with overcurrent and undervoltage relays suitable for motors with a power greater than 5 kilowatts?	No
28.	Are there any areas where liquid accumulates in the pool engine room? If so, is it drained?	No
29.	Are there insulated carpets and table in front of the panels in the pool engine room?	No
30.	Are the grounding installations and connections in the panels in the pool machine room appropriate?	No
ELEVATORS		CONDITION
31.	Are circuit protection fuses and automatic openers available?	Yes
32.	Are the power cable color codes appropriate?	Yes
33.	Have the necessary protective groundings been made?	No
34.	Are there 30 milliamp residual current protection relays in the panels?	No
ON THE COMMON USE DISTRIBUTION PANEL		CONDITION
35.	Are residual current protection relays properly installed and functional?	No
36.	Have the phase, neutral, protection, grounding and potential equalization conductors been used correctly in terms of color, cross-section, features and compliance with relevant standards?	No
37.	Do phase, neutral and protection lines reach all sorties? <i>partially, must</i>	<i>be checked.</i>
38.	Are the results obtained from the tests appropriate according to the regulation on grounding in electrical installations?	No.

6. WARNINGS AND RECOMMENDATIONS

The building main entrance switch must be a toroidal or 4-pole fire protection switch. Common use electrical distribution panel outputs should be checked, the residual current protection relays must be added to all phases. The fuse groups in the panels must be installed in accordance with selectivity. All cables in the pool engine room should be revised and all openly connected installations should be corrected. The panel grounding must be done. The pool engine room electrical panel must be grounded. Insulated should be laid in front of the main distribution panel. Lighting and electrical panels should be made suitable for damp areas.

	INTERNAL ELECTRICAL SUPPLY CONTROL FORM		
		Date of Issue	11 / 07 / 2025
		Date of Validity	11 / 07 / 2026

7. CONCLUSION AND OPINION

Regulations taken into account during the inspection; Regulation on Grounding in Electrical Installations, Electrical High Current Facilities Regulation and with the TS EN 60079 standards. Periodic inspection should be carried out again after the deficiencies are completed. on the date .././2025, this report has been prepared stating that there is no problem in using it safely for ONE YEAR, provided that the recommendations are followed.

8. APPROVAL

The document has been prepared in 2 copies, and the identity information of the person who issued the document and the institution official are stated below. 11/07/2025

<u>Controller</u>		<u>Company Executive</u>	
T.C. Kimlik No	29755012304	T.C. Kimlik No	
Adı Soyadı	Taner YILMAZ	Adı Soyadı	
Unvanı	Periyodik Kontrol Uzmanı	Unvanı	
İmza	 Taner YILMAZ Elektrik Elektronik Mühendisi Sicil No: 69534	İmza	

T.C.
ALANYA 1. NOTERLİĞİALANYA 1. NOTERİ
REŞAT DURANKILIRPINARI MAH.
YAKUBAT BULV.
KAT: 1PT. NO:150/A-
ALANYA / ANTALYA
T.C. 242.118830
T.C. 242.118834

İMZA BEYANNAMESİ

07026

Türkiye Cumhuriyeti resmi kurum ve kuruluşları, gerçek ve tüzel kişiler ile bankalarla yapacağım her türlü işlemlerde aşağıda örnekleri bulunan imzanı kullanacağımı, imzamın beni her bakımdan sorumlu kılacağını beyan eder, onaylanmasını talep ederim.

TANER YILMAZ - 29755012304


Çikilli Mah. Arıkanlar Cad. No: 27E / 13 Alanya / ANTALYA

İMZA

İMZA

İMZA

Bu Onaylama işlem altındaki imzanın gösterdiği Alanya Nüfus Müdürlüğü'nden verilmi 24/08/2012 tarih, 12782 kayıt, D13 seri ve 567752 numaralı fotoğraflı Nüfus Cüzdanının göre Antalya ili, Alanya ilçesi, Karakocalı mahallesi/köyü, 44 cilt, 3 aile sıra, 21 sıra numaralarında nüfusa kayıtlı olup, baba adı Tuncer , ana adı Mine , doğum tarih 20/8/1994 , doğum yeri Alanya olan ve halen yukarıdaki adreste bulunduğunu, okuryaza olduğunu bildiren 29755012304 T.C. kimlik numaralı TANER YILMAZ isimli kişiye ait olduğunu noterlikte huzurunda alındığını, onaylarım. Yirmialtı Şubat ikibinyirmibir Cuma günü 26/02/2021

ALANYA 1. NOTERİ
Reşat DURANYerine
İmzaya Yetkili Katip
Esra BAĞ



**T.C. ÇALIŞMA VE
SOSYAL GÜVENLİK BAKANLIĞI**



tmmob
makina mühendisleri odası

Tarih: 19.11.2021

Belge No: PKTE 04528

EKİPNET Geçici / Kalıcı Kayıt No: G21069786 / K21069786

**İŞ EKİPMANLARININ PERİYODİK KONTROLÜNÜ YAPMAYA YETKİLİ KİŞİLERİN TEMEL EĞİTİMİ
TAMAMLAMA BAŞARI BELGESİ**

TANER YILMAZ İş Ekipmanlarının Kullanımında Sağlık ve Güvenlik Şartları Yönetmeliğine göre düzenlenmiş eğitimi tamamlamış ve yapılan sınavda başarılı olarak iş ekipmanlarının periyodik kontrollerini yürütmeliği için bu belgeyi almaya ve EKİPNET sistemine kesin kayıt yaptırmaya hak kazanmıştır.

**Mesleği: ELEKTRİK-ELEKTRONİK
MÜHENDİSLİĞİ (İNGİLİZCE)
T.C. Kimlik Numarası: 29755012304**

TMMOB

**Makina Mühendisleri Odası
Adana Şube Başkanı**



TESCİL BELGESİ
2025
ELEKTRİK
1kV ÜSTÜ VE 1kV
ALTI TESİSLER

TC KİMLİK NO : 29755012304
ADI SOYADI : TANER YILMAZ
LİSANS UNVANI : ELEKTRİK ELEKTRONİK MÜHENDİSİ
ODA SİCİL NO : 69534
SMM NO : 07 07 69534
TESCİL TARİHİ : 22.01.2025
GEÇERLİLİK TARİHİ : 31.12.2025
BÜRO TESCİL NO : 07070350408275
BÜRONUN ÜNVANI : FENERCİOĞLU CASA PROJE MİMARLIK MÜHENDİSLİK
İNŞ.TUR.TİC.LTD.ŞTİ.
BÜRONUN ADRESİ : SUGÖZÜ MAH. SUGÖZÜ CAD. NO:95/A 07400 ALANYA ANTALYA
BAĞLANTI ŞEKLİ : ÜCRETLİ
FAALİYET ALANI : MÜHENDİSLİK HİZMETLERİ



1823UHKAKDD4

ONAY



e-İMZA

MAHİR ULUTAŞ

Bu SMM Belgesini alan yukarıda TC Kimlik Numarası, Adı Soyadı, Ünvanı ve faaliyet konusu yazılı üyemiz ilgili yasa, yönetmelik, şartname ve standartlara uygun olarak Serbest Müşavir Mühendislik Hizmetleri yapmaya yetkilidir. Bu belge sahibi mühendis, 6235 sayılı TMMOB yasası ve bu yasaya bağlı çıkarılan tüm tüzük, yönetmelik ve şartnameler uyarınca, ürettiği mühendislik hizmetlerini TMMOB Elektrik Mühendisleri Odası Mesleki Denetimi'ne sunmak zorundadır.

Bu belgenin doğruluğunu 1823UHKAKDD4 barkod numarası ile belgekontrol.emo.org.tr adresinden kontrol edebilirsiniz.

BÜRO TESCİL BELGESİ 2025

BÜRONUN ÜNVANI : FENERCİOĞLU CASA PROJE MİMARLIK
MÜHENDİSLİK İNŞ.TUR.TİC.LTD.ŞTİ.

BÜRONUN ADRESİ : SUGÖZÜ MAH. SUGÖZÜ CAD. NO:95/A
07400 ALANYA ANTALYA

FAALİYET ALANI : MÜHENDİSLİK HİZMETLERİ

VERGİ DAİRESİ VE NO : ALANYA 0350408275
BÜRO TESCİL NO : 07070350408275
TESCİL TARİHİ : 13.01.2025
GEÇERLİLİK SÜRESİ : 31.12.2025

ADI SOYADI / TC KİMLİK NO	ÜNVANI	SMM NO' SU
1 - TANER YILMAZ 29755012304	ELEKTRİK ELEKTRONİK MÜH.	07 07 69534



8FCZOE5591YN

ONAY



MAHİR ULUTAŞ
YÖNETİM KURULU

Büro Tescil Belgesi alan yukarıda TC Kimlik Numarası, Adı, Ünvanı ve Faaliyet Konusu yazılı
Üyemiz/Üyelerimiz ilgili yasa, yönetmelik, şartname ve standartlara uygun olarak serbest
müşavir mühendislik hizmetlerini yapmaya yetkilidir.

Bu belgenin doğruluğunu **8FCZOE5591YN** barkod numarası ile belgekontrol.emo.org.tr
adresinden kontrol edebilirsiniz.

